


No. 2014-BO-0644



Safety Certificate

DUON SYSTEM Co., Ltd

It is only for the product manufactured in 298-29, Gongdan-ro, Gunpo-si, Gyeonggi-do, Korea

The following product produced by the above company has been authorized for the use of the Mark  as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

PRODUCT

Smart level transmitter

TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL

ALT6100-HTHP

CERTIFICATION No.

14-AV2BO-0644X

CAPACITY · GRADE

Ex d IIC T4 IP67

16~45 Vdc

Tamb = -20 °C ~ +60 °C

SAFETY CERTIFICATION STANDARDS

Notification No. 2013-54 of the Ministry of Employment and Labor

CERTIFICATION CONDITION

1. It is only for the product manufactured in 298-29, Gongdan-ro, Gunpo-si, Gyeonggi-do, Korea
2. Surface temperature of product must not be exceed 130 °C when it is used.
3. Process Pressure : 400 Bar at 20 °C, Process Temperature : -20 °C ~ 400 °C

DATE : FEB. 15. 2016

NOV. 26. 2014(Original issue)

Signature

Lee, Young Soon

President of Korea Occupational Safety and Health Agency