


No. 2012-BO-0741-1



# Safety Certificate

DUON SYSTEM Co., Ltd

298-29, Gongdan-ro, Gunpo-si, Gyeonggi-do, Korea

The following product produced by the above company has been authorized for the use of the Mark  as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

## PRODUCT

Pressure Transmitter

## TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL

APT3500

CERTIFICATION No.

12-AV2B0-0741

CAPACITY · GRADE

Ex d IIC T6 IP67  
VDC : 12.5~45, Output : 4~20 mA or HART  
 $-20^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$ ,  $T_{\text{process}} \leq +80^{\circ}\text{C}$

## SAFETY CERTIFICATION STANDARDS

Notification No. 2010-36 of the Ministry of Employment and Labor

## CERTIFICATION CONDITION

It is only for the product manufactured in 298-29, Gongdan-ro, Gunpo-si, Gyeonggi-do, Korea

DATE : FEB. 15. 2016

NOV. 28. 2012(Original issue)

Signature

*Lee, Young Soon*

President of Korea Occupational Safety and Health Agency